

Tabela regulacyjna

Sieć przesyłowa na Os. Powstańców Śl.
Czynnik grzewczy o parametrach 135/70⁰C, Q=230m³/h

TEMPERATURY [°C]		
ZEWNĘTRZNA	ZASILANIA	POWROTU
-20	135,0	70
-19	133,0	69
-18	131,0	68
-17	128	67
-16	126	66
-15	124	65
-14	122	64
-13	119	63
-12	117	62
-11	115	60
-10	113	59
-9	110	58
-8	108	57
-7	105	56
-6	103	55
-5	101	53
-4	98	52
-3	96	51
-2	93	50
-1	91	48
0	88	47
1	86	45
2	85	46
3	85	47
4	85	48
5	85	50
6	85	51
7	85	52
8	85	53
9	85	54
10	85	55
11	85	60
12	85	62

Poza sezonem grzewczym na potrzeby CW:
temp. zas./powr. 90/55⁰C, Q=80m³/h